

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO. 7165-0028:144 Page 1 of 2

CATEGORY: Control Units (Non High-Rise)

LISTEE: Notifier, A Pittway Company, One Fire-Lite Place, Northford CT 06472-1653
Contact: Larry Flood (203) 484-1200

DESIGN: Model S5000. Power-limited; coded, non-coded or marchtime; local, auxiliary remote station and proprietary (protected premises) service; sprinkler supervisory and releasing device service. Refer to listee's data sheet for system description and operational considerations.
System components:

| | |
|---------------------------------|------------------------------------|
| CPU-5000 | Central Processor Unit |
| IZM-8 | Initiating Zone Module |
| VP-1 | Vented Dress Panel |
| BP-1 | Battery Dress Panel |
| MPS-24/MPS-24A/MPS-24B | Main Power Supply |
| CAB-A2/CAB-B2/CAB-C2/CAB-D2 | Enclosure |
| Gel Cell Battery | 24V, 9 - 25 Ah Battery |
| 71252 | EOL Resistor |
| CAB-A3/CAB-B3/CAB-C3/CAB-D3/ | |
| CAB-A3R/CAB-B3R/CAB-C3R/CAB-D3R | Enclosure |
| BP-3 | Power Dress Panel (CAB-3 series) |
| MPS-TR | Trouble Relay |
| UZC-256 | Universal Zone Coder |
| ZE-A | Initiating Zone Expander Module |
| AIM-200 | Addressable Intelligent Module |
| ICM-4 | Indicating Circuit Module |
| ICE-4 | Indicating Circuit Expander Module |
| TCM-2 | Time Control Module |
| CRM-4 | Control Relay Module |
| CRE-4 | Control Relay Expander Module |
| ARM-4 | Auxiliary Relay Module |
| AVPS-24 | Audio Visual Power Supply Module |
| CHS-4 | Chassis |
| MP-1 | Module Dress Panel |
| DP-1 | Blank Dress Panel |
| BM-1 | Blank Module |
| 71245 | Dummy Load Resistor |
| EFB-1 | Earth Fault Board |
| NIB-96 | Network Interface Board |

INSTALLATION: In accordance with listee's printed instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL label.

APPROVAL: Listed as control unit when used in conjunction with separately listed compatible initiating and indicating signal devices.*This control unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition. Refer to manufacturer's Installation Manual for details.

Proprietary Protected Premise Unit: the system is intended to be interconnected with Potter Model EFT-C Transmitter (CSFM Listing No. 7330-0328:104).

Central Station Protected Premise Unit: *Suitable for central station service when used with separately listed electrically compatible DACT.

*Corrected 06-05-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 7, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**